

Memorandum

To: Michael Campbell – Campbell Brown Planning Limited

From: Matt Jones

Date: 17 December 2021

Job No: 1628 M5

Subject: Wastewater Design for the proposed residential subdivision at 2182 East Coast

Road, Silverdale, Stages 3 and 4

This Memorandum has been prepared to detail the proposed wastewater drainage for the proposed Build Rich Limited Stage 3 and 4 residential development at 2182 East Coast Road, Silverdale. Stages 3 and 4 form the southern portion of the overall East Coast Heights development, please refer to figure 1 below:



Figure 1: overall East Coast Heights development



Stages 3 and 4 comprise 289 residential lots including two super lots containing 7 and 8 terraced units respectively. This results in a total of 302 household dwellings, please refer to figure 2 below:



Figure 2: extract of ASC Architects site plan of Stages 3 and 4

We have undertaken wastewater flow calculations in accordance with WSL CoP table 5.1.1 and 5.1.4. Please refer to the summary of wastewater flows tabulated in figure 3 below:



Zone	CATCHMENT (m²)	Gross Floor Area (GFA) (m²)	NO OF DWELLINGS (1/300m²)	NO OF DWELLINGS (15/ha)	CATCHMENT POPULATION (assumes 3 persons/dwelling)	ADWF (L/day)	PWWF (L/day)	ADWF (L/sec)	PWWF (L/sec)
Stage 3			164		492	88560	593352	1.03	6.9
Stage 4			53		159	28620	191754	0.33	2.2
Stage 5			70		210	37800	253260	0.44	2.9
Stage 6			7		21	3780	25326	0.04	0.3
Stage 7			8		24	4320	28944	0.05	0.3
TOTAL			302			163080	1092636	1.89	12.65

Figure 3: extract of wastewater flow calculations

The total wastewater flow (PWWF) for all 302 household dwellings is 12.65 litres/sec. The wastewater calculations attached demonstrate that a 150mm diameter uPVC pipe laid at a gradient of 1% has a capacity of 15.5 litres/sec.




Figure 4: preliminary wastewater network layout

It is proposed to provide wastewater drainage to the subdivision predominately with a gravity piped wastewater network and some lots serviced by pressure wastewater reticulation, as shown in Figure 4 above. The subdivision will discharge into the newly installed wastewater manhole in the north western corner of the site. This downstream wastewater system discharges to the new pump station (currently under construction) in the Botanic Retirement Village.



Due to the topography of the site 12 lots in the southwest corner (on Road-1 and Spine Road) of the site and 19 lots off Road-3 on the southern boundary will be serviced by a pressure wastewater reticulation system. Both these pressure systems will pump up into the upstream end wastewater manholes of the gravity system.

The 31 lots (Lots 1 to 4, 153 to 160, 167 to 175, 220 to 225 and 286 to 289 inclusive) above should have a private pump station installed at building consent stage. This requirement should form a consent notice on the title.

All lots and terrace units on the gravity network will be serviced by a 100mm diameter uPVC lot connection. All the 31 lots on pressure wastewater network will be serviced by a wastewater boundary kit.

Please refer to preliminary and general plans 1628-RC-PG101-105 and wastewater plans 1628-RC-WW501 to WW503 attached for the proposed wastewater system layout.

Please feel free to contact us if you require any further information.

Aspire Consulting Engineers Wastewater Flow



Job Number: 1628

Client: Build Rich Limited

Site Details: 2182 East Coast Road, Silverdale (Stages 3 & 4)

1. Use WSL Code of Practice for Subdivision and Development - Part 5 Wastewater

2. Flow Rates from WSL CoP Table 5.1.1 and 5.1.4

ADWF

			_
Urban	180	L/p/day	Table 5.1.1
General Business (GB)	4.33	L/m²/day	Table 5.1.4 Light water users, or up to 2 storeys
			Note: m ² only relates to GFA, assume 40% of total area
General Business (WR)	15	L/m²/day	Table 5.1.3 Wet retail

Peaking Factor	6.7

3. Calculate ADWF and PWWF for catchment

Zone	CATCHMENT (m²)	Gross Floor Area (GFA) (m²)	NO OF DWELLINGS (1/300m²)	NO OF DWELLINGS (15/ha)	CATCHMENT POPULATION (assumes 3 persons/dwelling)	ADWF (L/day)	PWWF (L/day)	ADWF (L/sec)	PWWF (L/sec)
Stage 3			164		492	88560	593352	1.03	6.9
Stage 4			53		159	28620	191754	0.33	2.2
Stage 5			70		210	37800	253260	0.44	2.9
Stage 6			7		21	3780	25326	0.04	0.3
Stage 7			8		24	4320	28944	0.05	0.3
TOTAL			302			163080	1092636	1.89	12.65

Wastewater Pipe Check



Job Number: 1628

Client: Build Rich Limited

Site Details: 2182 East Coast Road, Silverdale (Stages 3 & 4)

Post Development Flow Volume (Refer Sheet 1)

PIPE CAPACITY FORMULA (Full Flow)

Colebrook-White V=- $2\sqrt{(2gDS)}\log(ks/3.7D+2.51\upsilon/(D\sqrt{(2gDS))})$

υ= 1.141 x10⁶ kinematic viscosity of fluid

(water at 15 degrees)

k_s= 1.5 mm (effective roughness)

D= diameter

S= hydraulic gradient

R= d/4 (circ. pipes)

Q= VA

Capacity Check on 150mm diameter uPVC

Pipe	Pipe	Pipe	PIPE				
Grade	Dia D	Vel'y	CAP'Y				
S(%)	(m)	(m/s)	(l/s)				
1.0	150	0.88	15.5				

Therefore pipe has adequate capacity to cater for development

1628 WW flows

BUILD RICH LIMITED 2182 EAST COAST ROAD SILVERDALE EAST COAST HEIGHTS - STAGE 3 & 4 RESOURCE CONSENT PLANS



PG100 - PRELIMINARY & GENERAL

EW200 - EARTHWORKS

RD300 - ROADING

SW400 - STORMWATER

WW500 - WASTEWATER

WS600 - WATER SUPPLY



SITE LOCALITY



COVER SHEET PG101

JOB NUMBER: 1628

RESOURCE CONSENT DRAWINGS:

PRELIMINARY & GENERAL PG100

PG101 COVER PAGE

PG102 CONTENTS PAGE

PG103 EXISTING SITE PLAN

PG104 PROPOSED DEVELOPMENT OVERVIEW

PLAN

PG105 PROPOSED STAGING PLAN



SITE LOCALITY



NOT FOR CONSTRUCTION FOR RESOURCE CONSENT PURPOSE

JOB NUMBER: 1628

REV.	DESCRIPTION	CHECK	APP'D DATE	SCALE N.T.S A	Г А3		CLIENT	SITE ADDRESS	DRAWING NUMBER		
					NAME	DATE		2182 EAST COAST ROAD	4000 50 5	0.400	
				DESIGN	JH	12.21	BUILD RICH LIMITED	SILVERDALE (STAGE 3 & 4)	1628 - RC - P	G102	
				DRAWN	JH	12.21		` ,	DATE	DEVISION	CONSULTING ENGINEERS
				DRAWING CHECK	PF	12.21		DRAWING TITLE	DATE	REVISION	CONSCENING ENGINEERS
				DESIGN CHECK	PF	12.21	Conditions of Use: These drawings shall only be used for the purpose for which they were supplied. Do not measure off this drawing. If doubt please contact Engineer.	CONTENTS PAGE	DEC 2021 -		Ph: 09 426 6552
				APPROVED	PF	12.21			 .		Web: www.aspeng.co.nz

