

Isobel Lee

From: Roshanak Rezaee s 9(2)(a)
Sent: Tuesday, 21 March 2023 3:45 pm
To: Isobel Lee
Cc: Philip Brown; Michelle Kemp; Sam Sarah
Subject: RE: Metlifecare Whenuapai - Outlet Structure Query

Hi Isobel

We have been advised by our survey team that MHWMS is RL3.3, so I believe our SW outlet will sit above this level.

MHWMS is at RL 3.30 in terms of NZ Vertical Datum 2016

Steve Wardle
Team Leader Survey

Regards

Roshanak Rezaee
Team Leader – Land Development

M s 9(2)(a)
D +64 9 212 6580
P +64 9 917 5000

harrisingrierson.com



Warning: This email and any attachments are confidential and intended exclusively for the addressee(s). They may also be subject to copyright and legal privilege. Any unauthorised review, copying, disclosure or use of any of the contents is prohibited. If you receive this email in error, please immediately notify us by return email, and delete all copies of the email and any attachments.

From: Isobel Lee s 9(2)(a)
Sent: Tuesday, 21 March 2023 2:29 pm
To: Roshanak Rezaee s 9(2)(a)
Cc: Philip Brown s 9(2)(a); Michelle Kemp s 9(2)(a)
Subject: Metlifecare Whenuapai - Outlet Structure Query

Hi Roshanak,

Thank you for your time on the phone earlier.

As discussed, we are wondering if the structure for the below proposed stormwater outlet will be located above the Mean High Water Spring? This is to help us determine consenting matters regarding the Coastal Marine Area that borders the site and an indication that the stormwater outlet structure will be located above the MHWS would make it a lot clearer from a consenting perspective. Please let me know if you need any further information.



I look forward to receiving your response.

Kind regards,

Isobel

Isobel Lee | Intermediate Planner | BUrb Plan (Hons) | Int. NZPI

Campbell Brown Planning Limited

Level 2, 46 Brown Street, Ponsonby | PO Box 147001, Ponsonby, Auckland 1144

Ph 09 378 4936 | DDI 09 394 1699 | s 9(2)(a) | www.campbellbrown.co.nz



DISCLAIMER: This electronic message together with any attachments is confidential. If you are not the intended recipient, do not copy, disclose or use the contents in any way. Please also advise us by return e-mail that you have received the message and then please destroy. We are not responsible for any changes made to this message and/or any attachments after sending. We use virus scanning software but exclude all liability for viruses or anything similar in this email or any attachment. Views expressed in this email may not be those of [Campbell Brown Planning Limited](http://www.campbellbrown.co.nz)

Please consider the environment before printing this email.