



ENVELOPE ENGINEERING
LAND
STRUCTURE
MANAGE





INFRASTRUCTURE ASSESSMENT

OTAKI MAORI RACING CLUB

DOCUMENT CONTROL RECORD

CLIENT	Ōtak Revisited Limited
PROJECT	Ōtak Māori Racing Club
PROJECT NO.	1733-01
DOCUMENT TYPE	R001-v2-1733-01 OMRC Infrastructure Assessment Report
DATE ISSUED	27 October 2022
ADDRESS FOR SERVICE	Envelope Engineering Limited Level 1 65 Cuba Street Te Aro Wellington 6011
CONTACT	Louise Ireland s 9(2)(a) s 9(2)(a)

ISSUE AND REVISION RECORD

DATE OF ISSUE	27 October 2022
STATUS	Issued 
ORIGINATOR	Louise Ireland – Civil Engineer 
REVIEWED	Andrew Jackson – Director Civil 
APPROVED FOR ISSUE	Matt Atchison – Project Manager / Senior Civil Engineer 



CONTENTS

1.0	INTRODUCTION	1
2.0	PROPOSED DEVELOPMENT.....	1
3.0	EARTHWORKS.....	2
3.1	EROSION AND SEDIMENT CONTROL	2
3.2	EARTHWORKS APPROACH	3
4.0	STORMWATER	3
4.1	EXISTING INFRASTRUCTURE	3
4.2	FLOOD HAZARD	3
4.3	PROPOSED INFRASTRUCTURE	4
5.0	WASTEWATER.....	4
5.1	EXISTING INFRASTRUCTURE	4
5.2	PROPOSED INFRASTRUCTURE	4
6.0	POTABLE WATER	5
6.1	EXISTING INFRASTRUCTURE	5
6.2	PROPOSED INFRASTRUCTURE	5
7.0	UTILITIES.....	6
8.0	SUMMARY	7

APPENDICES

APPENDIX 1 HYDRAULIC ANALYSIS LIMITED REPORT



1.0 INTRODUCTION

This report has been prepared to provide an overview of the existing infrastructure surrounding the Ōtak Māori Racing Club and on the potential for these services to service the development to support a fast-track consent application with the Ministry for the Environment for development at the site.

In order to utilise the fast-track consenting process a referral application must be approved by the Minister for the Environment. It is understood that the referral application must include details relating to the proposed servicing of the development and confirmation whether any on-site or off-site upgrades or additional infrastructure may be required to service the development. This Assessment seeks to satisfy these requirements.

2.0 PROPOSED DEVELOPMENT

It is proposed to develop the Ōtak Māori Racing Club into a comprehensive village development. This will consist of approximately 400 – 580 residential sections and units including standalone houses, townhouses, apartments and cluster housing. A commercial area is proposed in the northeast of the site (Zone D) together with the redevelopment and reuse of existing commercial buildings within the site. The development can be broken up into seven distinct zones (Zones A – G) with zones A – as proposed development areas and zone G containing the existing racing club buildings (grandstand and associated facilities). The existing racetrack and club buildings are to be retained as a fully functional racecourse.

To date several activities have been carried out to determine appropriate development concepts for the site. Assessments were then undertaken by experts from several disciplines against these concepts. A summary of these activities is listed below.

- Numerous site visits have been carried out by Envelope staff, other consultants and key stakeholders.
- Meetings, discussions and workshops with Development and Engineering staff from Kapiti Coast District Council and Greater Wellington Regional Council about infrastructure servicing, stormwater management and treatment and earthworks issues.
- Meetings with mana whenua.
- Meetings with key stakeholders.





Figure 1. Development zoning designations (Moller Architects)

3.0 EARTHWORKS

3.1 EROSION AND SEDIMENT CONTROL

Any disturbance to existing ground removes the existing vegetative cover and potentially allows erosion of the bare ground to occur. The granular sandy and gravel soils found on site are less prone to erosion than more clayey materials found in hilly areas of the Ōtaki region. The flat nature of the site is also an aspect which means there is likely to be less mobilisation of soils. The risk of generating erosion is proportional to the surface area exposed, the duration of earthworks, the steepness of the earthworks area and the rainfall occurrences during the earthworks process.

The fast-track consent will include seeking earthworks consent from both Kapiti Coast District Council and Greater Wellington Regional Council. Principles of Erosion and Sediment control that will be assessed at the fast-track consent stage include:

- Minimise disturbance – Minimise the extent of earthworks as much as practicable
- Stage construction – Minimise the amount of area open at one time and the time that these areas are left un-stabilised
- Protect receiving environments – Apply additional protection (e.g. silt fences) and work methodologies around sensitive receiving environments (near stream corridors etc)
- Rapid stabilisation – Progressively stabilise disturbed areas as soon as practicable
- Perimeter controls – Installation of perimeter controls for the diversion of clean water around the earthworks extent and separate this from sediment-laden water within the site
- Employ sediment retention devices – Install treatment devices to maximise the efficiency of sediment removal within treatment devices
- Review – Review and revise the effectiveness of erosion and sediment controls on a regular basis to ensure that they are still effective and applicable to the current site conditions

These are the fundamental elements of good practice that should be common to all sites. These limit the opportunity for erosion; however, even with best practice, there will always be the risk of some sediment being mobilised during and immediately after rainfall events. Therefore, it is equally important to put in



place control measures to contain, collect and manage any sediment that is generated before it can leave the site. The GWRC guidance document "Erosion and Sediment Control Guide for Land Disturbance Activities" in the Wellington Region details control measures and is widely used as the appropriate standard for management of erosion and sediment control in the Wellington Region.

It is our view that the erosion and sediment control design can be adequately addressed through future consents to ensure that potential adverse effects can be managed and mitigated to an acceptable level. We consider that subject to employing the measures outlined above there will be no significant adverse effects relating to the proposed earthworks.

3.2 EARTHWORKS APPROACH

The site is relatively flat and it is proposed to modify the existing ground as little as possible while forming minimum floor levels above identified flood heights. While earthworks are likely across a large area due to the site size and for flood mitigation (discussed in Section 4) an earthworks balance will be targeted so that minimal material is required to be brought onto or taken off site. Material unsuitable for earthworks will be used on site (e.g. in landscaping areas) where this is feasible.

It is our view that earthworks design can be adequately addressed through future consents.

4.0 STORMWATER

4.1 EXISTING INFRASTRUCTURE

There is no existing public stormwater infrastructure at the site. A modified stormwater channel runs along the east boundary of the site and along Rahu Road to the north of the site before crossing the road and entering Te Awahonui Drain north of the site. There are several existing culverts that are located on the channel within the site.

To support the proposed development stormwater management measures will need to be employed on site. Resource consent from Kapiti Coast District Council will be required for stormwater discharges and discharge permits will be required from Greater Wellington Regional Council.

4.2 FLOOD HAZARD

The current flood hazard mapping is shown in Figure 2. This shows that parts of the site are subject to ponding, residual ponding, residual overflow and within stream corridors. We understand that the residual ponding and residual overflow areas are historical overlays from prior to the Chrystalls Bend flood protection improvements. Other ponding areas on site are largely shallow in nature (from GIS maps) except for isolated areas.

Updated flood models are being prepared to inform development on the site. These will assess the existing flood hazard and flood hazard post-development with mitigation measures implemented within the model to assess on and off-site effects.

It is expected that some form of flood mitigation will be required. This will likely consist of the creation of dedicated flood storage areas on site where water is allowed to pond and widening of the existing stormwater drains to allow for natural build-up in these areas. Allowance for these areas has been provided on the masterplan.

Based on the preliminary flood modelling results the proposed improvement measures (including the flood storage areas) will appropriately address the existing flood hazard at the site as well as mitigating any increase in stormwater runoff associated with the development. In this regard, the proposed stormwater concepts and measures have been designed on the basis that the development will achieve hydraulic neutrality.

It is our view that flood modelling and assessment of flood hazards can be adequately addressed through future consents. In short, the assessments and modelling undertaken to date confirms that appropriate measures can be employed (as have been allowed for in the masterplan design) to ensure potential adverse effects associated with stormwater discharge or with undertaking earthworks and development within the existing flood areas can be adequately mitigated.






Figure 2. KCDC GIS flood map of the site and surrounding area

4.3 PROPOSED INFRASTRUCTURE

Hydraulic neutrality will be achieved using local and/or centralised soakage devices (where ground soakage rates permit) and storage ponds which may be integrated into the flood mitigation areas where this is possible.

Stormwater runoff from public roadways would need to pass through a treatment device prior to connecting to the new public stormwater network and ultimately discharging to the natural environment at the stormwater channels. This is likely to be by roadside drainage gardens or centralised treatment wetlands.

The stormwater system will be designed with the principles of Te Mana o te Wai and Water Sensitive Urban Design in mind. This will be done by preserving various watercourses and vegetated areas around the property treating stormwater runoff and peak flow attenuation.

It is our view that the design of stormwater infrastructure can be adequately addressed through future consents. Based on the assessments undertaken to date, it is our view that no significant adverse effects will arise as a result of the proposed stormwater servicing and flood hazard mitigation works.

5.0 WASTEWATER

5.1 EXISTING INFRASTRUCTURE

There are existing 150mm diameter gravity wastewater pipes running along Te Roto Road and Rahu Road to the northwest and northeast of the site. While the condition of these pipes is unknown, Kapiti Coast District Council have advised they are currently going through a process of modelling existing wastewater constraints within the wider catchment.

The wastewater is collected at a pump station on the intersection of Rahu Road and Te Roto Road. This discharges to a gravity sewer line which runs to a second pump station on County Road. From here, the wastewater is conveyed through a series of gravity pipes, pump stations and rising mains to the central wastewater treatment plant on Rerbank Road.

Hydraulic Analysis Limited have assessed the existing capacity of the gravity pipes in the vicinity of the development. The gravity sewer pipe along Te Roto Road has sufficient capacity for up to 209 total dwellings (including existing dwellings) and the pipe along Rahu Road is already at design capacity.

5.2 PROPOSED INFRASTRUCTURE

As noted above, detailed network modelling is currently being undertaken by Kapiti Coast District Council to inform the proposed development. Initial feedback suggests that there will be upgrades required to the



pump stations on Te Roto Road, County Road and Arthur Street with various upgrades expected to the rising mains and gravity pipes to the wastewater treatment plant

Kapiti Coast District Council has secured funding for the upgrades via the Infrastructure Acceleration Fund. Based on the proposed development timeframes and our discussions with Kapiti Coast District Council, it is expected that the upgrade of these will coincide with the requirements of the development. Relevant staff at Council have confirmed that the upgrade works can be programmed to align with the delivery of the development.

We expect that wastewater mitigation will be required in the form of pumping stations. These could be incorporated into the wider network upgrades provided for within the development or as upgrades to operational storage on existing pump stations. These decisions will be informed by the results of the detailed network modelling.

It is our view that the design of wastewater infrastructure can be adequately addressed through future consents, further given that Kapiti Coast District Council have received funding for the necessary wastewater upgrades, are undertaking the necessary modelling to confirm the extent of works, and have confirmed that such works can align with the proposed development, there are no impediments to advancing this work to ensure the necessary wastewater infrastructure is available for the proposed development.



Figure 3. Wastewater network connectivity of the site

6.0 POTABLE WATER

6.1 EXISTING INFRASTRUCTURE

There is an existing 150mm diameter water main located within Rahu Road which is supplied by the Waiohau Valley Reservoir. The base elevation of the reservoir is RL100 with the site having typical elevations of RL15 to RL20.

6.2 PROPOSED INFRASTRUCTURE

Detailed network modelling is currently being undertaken for the development by Kapiti Coast District Council with results not yet available. However, we understand that a new reservoir will be required to serve the new development and that this will be located near Rongawhata Road. Kapiti Coast District Council have secured funding for this through the Infrastructure Acceleration Fund and we understand



from our discussions with Council that the works will be undertaken to align with the delivery programme for the development

Based on our discussions with Kapiti Coast District Council we understand that a new water main will be required from County Road which will be gravity fed by the proposed reservoir. Subject to detailed hydraulic modelling it is expected that adequate supply of water for firefighting and potable water can be supplied to the development. It is expected that the alignment of this new main can be accommodated within public land (existing road corridors).

It is our view that the design of potable water infrastructure can be adequately addressed through future consents. Further given that Kapiti Coast District Council have received funding for the necessary potable water upgrades and are currently programming such works, there are no impediments to advancing this work to ensure supply is available for the proposed development.



Figure 4. Potable water network connectivity of the site (proposed upgrades not shown)

7.0 UTILITIES

We have contacted Chorus who have advised that there is existing infrastructure in the area surrounding the site and that this can be extended and upgraded where required to service the development.

A power supply network is available adjacent to the site. We have had preliminary discussions with the Network Utility Operator (Electra) who have advised us that upgrades will be required from Otaki town centre to the proposed development. This can occur within existing public road corridors.

Ret culated gas is not proposed for the development and as such we have not contacted the Network Utility Operator to establish if there is sufficient capacity in the existing infrastructure to service the development.

It is our view that the design of utilities infrastructure can be adequately addressed through future consents.



8.0 SUMMARY

This memo has been prepared to provide an overview of the existing infrastructure surrounding the Ōtak Māori Racing Club and the potential for these services to support the proposed development.

Three water infrastructure will be designed to Council standards. The final design will be developed in consultation with District Council to achieve an acceptable outcome with regard to the Council's District Plan and Subdivision and Development Principles and Requirements document.

The resource consent application will include an Infrastructure Report that provides full details of the proposed servicing of the Project. In addition, a Stormwater Management Plan will outline how stormwater will be appropriately managed on the site.

In summary, it is our view that the site can be developed and adequately serviced subject to further engineering design and that this can be addressed through future consents. Further, as Kapiti Coast District Council has received the necessary funding for off-site infrastructure upgrades to support the development and has already commenced the necessary modelling and design work to advance these upgrades, there appear to be no impediments to implementing the proposed development based on the delivery programme provided with the referral application.



APPENDICES

APPENDIX 1 HYDRAULIC ANALYSIS LIMITED REPORT

KAPITI COAST DISTRICT COUNCIL

OTAKI RACECOURSE DEVELOPMENT IMPACT ASSESSMENT


JULY 2022




HYDRAULIC
ANALYSIS
LIMITED

QUALITY SECTION

AUTHOR

Name	Title	Organisation	Signature
Sherine Sathiasothy	Experienced 3-Waters Engineer	Hydraulic Analysis Ltd	

REVIEWED

Name	Title	Organisation	Signature
Brian Robinson	Director	Hydraulic Analysis Ltd	

REVISION HISTORY

Revision	Publication Date
Draft	20 July 2022

DISCLAIMER This report has been prepared solely for the benefit of Kapiti Coast District Council with respect of the particular brief and it may not be relied upon in other contexts for any other purpose without Hydraulic Analysis Limited's prior review and agreement. Hydraulic Analysis Limited accepts no responsibility with respect to its use, either in full or in part, by any other person or entity.



CONTENTS

1. INTRODUCTION	1
1.1. Objective	1
1.2. Background	1
2. SCOPE	1
3. OTAKI RACECOURSE DESIGN FLOWS	2
3.1. Overview	2
3.2. Development Design Flows.....	2
4. OTAKI RACECOURSE DEVELOPMENT IMPACT.....	4
4.1. Pre-Development Scenario	4
4.2. Post-Development Scenario.....	4
4.3. Pump Station Assessment	6
4.3.1. OSP0001 Pump Station	6
4.4. PREVIOUS DEVELOPMENT KNOWLEDGE	7
5. MODEL ASSUMPTIONS AND LIMITATIONS	10
6. CONCLUSION	11



1. INTRODUCTION

1.1. OBJECTIVE

The objective of this study is to utilise the existing hydraulic model of the Otaki wastewater network (Aurecon, 2009, with 2020 updates undertaken by HAL) to assess the impact of the proposed Otaki Racecourse development on the wastewater network. The existing modelled populations have been updated by HAL to provide an estimated existing (2018) and future (2043) population scenario.

1.2. BACKGROUND

Otaki is the third largest township in the Kapiti region with a 2018 population of 7,300 (2018 census). The topography of the Otaki catchment is relatively flat and is separated into two parts on the east and west by a green belt. Otaki Beach is located to the west of the catchment and the Otaki River to the south. The bulk of the sewerage system was laid in the early part of the 1980s and incorporates a number of pumping stations (32 at the time of writing) to support development in low lying areas of the catchment.

The discharge to the Otaki Wastewater Treatment Plant (WWTP) is controlled by a major pumping station (Otaki Terminal Station PS12 - OSP00012). The wastewater from this system is treated by a combination of oxidation pond, clarifier and aerated lagoon at the Otaki WWTP before discharging to a landfill disposal system (Source: Otaki Sewerage System Model Build & Calibration Report, Aurecon 2009).

Significant growth is forecast for Otaki over the next 25 years, with KCDC's latest 'medium growth scenario' estimates showing a projected population of the Otaki catchment of 10,400 in 2043 (a 42% increase from 2018).

The planned development of 700 units of residential dwellings and 1250m² of low water use commercial space at the Otaki Racecourse is located south-east of the Otaki wastewater network. It is proposed that the development is connected to the existing 150mm sewer along Te Roto Road which flows north-east via gravity to the Rahui Rd Wastewater Pump Station (OSP0001), located at the intersection of Rahui Road and Te Roto Road.

2. SCOPE

The following tasks were undertaken as part of this assessment:

- Calculation of design flows for the Otaki Racecourse development
- Assessment of the Otaki Racecourse development impact on the existing network for both current (2018) and future population scenarios

Each of these tasks is discussed in more detail in the following sections.

3. OTAKI RACECOURSE DESIGN FLOWS

3.1. OVERVIEW

The Otaki Racecourse proposal seeks to develop a vacant site at the racecourse, along Rahui Road into a 700-lot residential development and 1250m² low water use commercial space. The location of the proposed development and proposed connection points is shown in Figure 3-1 below.




FIGURE 3-1 PROPOSED OTAKI RACECOURSE DEVELOPMENT LOCATION

The proposed discharge points for the development are to the 150mm pipeline on Te Roto Road (Zone A&B), and to the 150mm pipeline on Rahui Rd (Zones C-F), both of which drain to the Rahui Rd Wastewater Pump Station (OSP0001) located at the intersection of Rahui Road and Te Roto Road. The connecting network flows west of the catchment via a series of gravity network and pump stations, and eventually terminates at the Otaki WWTP.

The feasibility and sizing of the internal site connections, particularly with respect to adequate grade for gravity flow and the sizing of the private pump station, if any, has not been assessed as part of this study.

3.2. DEVELOPMENT DESIGN FLOWS

The PWWF for this development assessment has been calculated using the proposed 700 residential lot yield and 1250m² commercial space as provided in the concept plan.

Following the KCDC 'Subdivision and Development – Principles and Requirements' code the design flow formulas as shown below in Table 3-1 can be used to calculate a proposed residential and commercial Peak Wet Weather Flow (PWWF) of 25.6 l/s for the development.

TABLE 3-1: OTAKI RACECOURSE DESIGN FLOWS

	Residential Lots
No. of Units	700
Occupancy	2.5
Population	1750
ADWF (l/p/day)	250
ADWF (l/s)	5.06
DWF Peaking Factor	x2.5
PDWF (l/s)	12.7
WWF Peaking Factor	x5
PWWF (l/s)	25.3 l/s

	Commercial Space
Area (Ha)	0.125
Industry Type	Low water use
Design Flow (l/s)	0.4
ADWF (l/s)	0.05
WW Peaking Factor	5
PWWF (l/s)	0.25

4. OTAKI RACECOURSE DEVELOPMENT IMPACT

4.1. PRE-DEVELOPMENT SCENARIO

The Otaki wastewater model (Aurecon, 2009) with HAL 2020 updates, was run for a 24-hour, 5-year ARI nested design storm to assess how the local network performs during storms of this magnitude, without the proposed Otaki Racecourse development.

The standard design storm of 5-year ARI (which is the level of service (LOS) recently adopted by KCDC) has been used as the containment standard for this assessment.

As shown in the Figure 4-1 long section below, the existing 150mm gravity network flowing north-east from the development site to Pump Station OSP00001 shows minor surcharge in the section of pipeline immediately downstream from the discharge point. This indicates a minor existing capacity constraints in the immediate downstream gravity network and pump station, but not resulting in an unacceptable risk of overflows.




FIGURE 4-1 PRE-DEVELOPMENT FLOWS TO OSP00001 – 5-YEAR ARI DESIGN STORM

4.2. POST-DEVELOPMENT SCENARIO

The Otaki wastewater model (Aurecon, 2009) with HAL 2020 updates was run for a 24-hour, 5-year ARI nested design storm to assess how the local network performs in the post development scenario. The standard design storm of 5-year ARI (which is the recently adopted LOS by KCDC) has been used as the containment standard for this assessment. The model used the additional 25.6 L/s that was created by the proposed 700 residential dwellings and commercial space. This was connected to the existing Manhole KWWN000523.

As shown in the Figure 4-2 long-section below, in the post development scenario the downstream 150mm network flowing north-east to Rahui Road Pump Station (OSP00001) shows significant surcharge and uncontrolled manhole overflow at Manhole OSM00469, along

the pipeline downstream from the discharge point, indicating capacity constraints in this section of the network. For the scenario with future development yields connected to the network, as shown in Figure 4-3, the surcharge and overflow volume at Manhole OSM00469 are further exacerbated.




FIGURE 4-2 EXISTING SCENARIO WITH POST-DEVELOPMENT FLOWS (25.6 L/S) TO OSP00001 – 5-YEAR ARI DESIGN STORM




FIGURE 4-3 FUTURE SCENARIO WITH POST-DEVELOPMENT FLOWS (25.6 L/S) TO OSP00025 – 5-YEAR ARI DESIGN STORM

4.3. PUMP STATION ASSESSMENT

4.3.1. OSP0001 PUMP STATION

The local network flows northwest via gravity to Pump Station OPS0001, which has a modelled capacity of 13 l/s (based on KCDC records). The existing pre-development scenario has a modelled peak inflow of approximately 13.1 l/s in the 5-year design storm, which suggests that the existing pumpstation (and associated rising main infrastructure) is already operating at capacity and does not have the pass forward capacity for the additional flows from the proposed Otaki Racecourse development.

Modelled inflows and outflows for the pre-development scenario, is shown in Figure 4-5 below.




Figure 4-5 PRE-DEVELOPMENT AND POST-DEVELOPMENT OSP00001 PUMP STATION FLOWS – 5-year ARI DESIGN STORM

The network capacity downstream of Rahui Road pumpstation was not assessed as the flows are governed by the existing Rahui Road pumpstation capacities; increasing the Rahui Road pumpstation capacity will only result in a domino effect downstream of the network, requiring further upgrades works up to the Otaki Wastewater Treatment Plant.

4.4. PREVIOUS DEVELOPMENT KNOWLEDGE

There is an additional known development within the Rahui Road Pump Station (OSP00001) wastewater catchment, at the Otaki Maori Racing Club, for which a Resource Consent application was lodged with KCDC and assessed by HAL in February 2018. The calculated PWWF from this development is 1.52 l/s and it was concluded the local 150mm wastewater line running north-east along Te Roto Road to the Rahui Wastewater Pumpstation has sufficient capacity in both the existing and future scenarios, including with the proposed 209 dwellings assumed to connect to the Te Roto Road pipeline (which appears to encompass the area of the previously proposed Otaki Maori Racing Club development).

The location of the development is shown in Figure 4-4 below.




FIGURE 4-4 PLANNED DEVELOPMENT UPSTREAM OF RAHUI RD WASTEWATER PUMP STATION (OSP00001)

4.5. OTAKI RACECOURSE WASTEWATER NETWORK

It's worth noting that future upgrade options for the Otaki network for a range of ARI storms was investigated as part of the recent Level of Service review study (Morphum/Hal – 2020) and the output of this study is a set of future upgrade solutions to meet the preferred level of service. For Otaki Catchment, the recommended 10 year works programme includes an upgrade of the 150mm diameter wastewater line, along Rahui Road, which is identified as "Issue Area OT04".

The recommended upgrades from the study are shown in Figure 4-4 below.




FIGURE 4-4 RECOMMENDED NETWORK UPGRADES FOR OTAKI – 2020 LEVEL OF SERVICE STUDY

However, to create sufficient passforward capacity for the additional peak flows of 25.57 l/s, the entire downstream network from the discharge point to the Otaki Treatment Plant, including the pumpstations, needs to be upgraded. Hence, it is recommended that the developer design and construct a separate wastewater network to cater for the peak flows from the development site, assumed to follow a similar alignment as the existing public network, but to be confirmed as part of the design process.

Below is an indicative alignment duplicating the existing network, with the pumpstation around the same location. The developer will need to calculate the required pipe sizing, pumpstation capacity and alignment during the concept/detailed design stage. There is potential for the new network to resolve some of the existing/future capacity constraints identified in the 2020 Level of Service study, so consultation is recommended with KCDC to enable any efficiencies and potential cost sharign arrangements to be identified.

An indicative alignment (following the existign alignment) of the new network for the proposed development is shown in Figure 4-4 below.




FIGURE 4-5 INDICATIVE ALIGNMENT OF THE WASTEWATER NETWORK FOR OTAKI RACECOURSE PROPOSED DEVELOPMENT SITE

5. MODEL ASSUMPTIONS AND LIMITATIONS

The following assumptions should be read in conjunction with the following reports:

- Aurecon's report 'Paraparaumu Wastewater System – Model Build and Calibration' Report, June 2009
- Watershed's Model Update Report (2016)
- Watershed's Model Recalibration and System Performance Report (2017)
- Morphem's report 'Setting a containment standard based on a cost benefit analyses and confirming the 10 year works programme' Report, February 2021

The following limitations apply to the modelling undertaken as part of these studies:

- The model has been verified (and recalibrated) against flows developed from KCDC pump station SCADA data, and as such has an inherent limitation to the degree of accuracy able to be achieved.
- The distribution of the modelled population is an approximation based on the population increase between the 2006 and 2018 census. No allowance has been made for additional growth since 2018 which is considered to be minor.
- Future growth has been distributed within the currently modelled extent, based on KCDC's projections at an area unit level. It is unlikely to accurately represent specific locations of large future developments, which will need to be considered on a case by case basis.
- Flows from new development have been applied to result in approximately Code of Practice wet weather flows in a 5 year ARI design storm
- An allowance has been made in the future growth model (2043) for increased inflow/infiltration in existing areas due to deterioration of existing sewers.
- Pump station model parameters are based on information provided by KCDC operations, and its accuracy has not been validated as part of these studies.
- The Otaki Wastewater Treatment Plant storage capacity was not assessed with the additional inflow from the Racecourse Development.

6. CONCLUSION

The objective of this study is to utilise the existing hydraulic model of the Otaki wastewater network to assess the impact of the proposed Otaki Racecourse Road development. The proposal seeks to develop an existing vacant site into 700 residential dwellings and 1250m² commercial space development.

The model was run for the existing and future population scenarios, with the additional PWWF of 25.6 l/s from the proposed Otaki Racecourse Road development. The development impact on the immediate network was assessed against a 5-year ARI design storm.

During the post development scenario, with existing population, the downstream 150mm network flowing to Rahui Road Pump Station (OSP00001) shows significant surcharge and uncontrolled manhole overflow at Manhole OSM00469, along the pipeline downstream from the discharge point, indicating capacity constraints in this section of the network (also due to inadequate pump station capacity). For the scenario with future development yields connected to the network, the surcharge and overflow volume at Manhole OSM00469 are further exacerbated.


OSP00001 has a modelled capacity of 13 l/s (based on KCDC records). With a pre-development modelled inflow of 13.1 l/s in the existing scenario, the pump station (and associated rising main infrastructure) is already operating at capacity and cannot cater for the additional flows from the proposed development.

It should be noted that future upgrade options for the Otaki network for a range of ARI storms was investigated as part of the current Level of Service review study and the output of this study is a set of future upgrade solutions to meet the preferred level of service. For Otaki Catchment, the recommended 10 year works programme includes an upgrade of the 150mm diameter wastewater line, along Rahui Road, which is identified as "Issue Area OT04".

However, to create sufficient passforward capacity for the additional peak flows of 25.6 l/s, the entire downstream network from the discharge point to the Otaki Treatment Plant, including the connecting pumpstations needs to be upgraded. Hence, it is recommended that the developer design and construct a wastewater line to cater for the peak flows from the development site, following the same alignment as the existing public network.

There is potential for the new network to resolve some of the existing/future capacity constraints identified in the 2020 Level of Service study, so consultation is recommended with KCDC to enable any efficiencies and potential cost sharign arrangements to be identified.

Below is an indicative alignment duplicating the existing network, with the pumpstation around the same location. The developer will need to calculate the required pipe sizing and alignment during the concept/detailed design stage.



The Otaki Wastewater Treatment Plant storage capacity was not assessed with the additional inflow from the Racecourse Development.