

FNDC Abatement & Infringement Register (RMA)

updated: 13/08/2020

SCHEME/ASSET	Asset Type	CONSENT	TYPE	ISSUED DATE	CONDITION	BRIEF DESCRIPTION	Reason	Notice Number	Status	Date Cancelled (if applicable)	Comments
Kerikeri WWTP	Wastewater	AUT.004111.01.05	Abatement	24-Jul-20	8	Contravention of condition 8 of AUT.004111.01.05. Must comply on or before 30 November 2020.	Discharge of non-compliant wastewater.	EAC.070076.01	Current		Review in December 2020/January 2021 - Once new WWTP is commissioned this abatement notice should be removed. Consent is based on plant having been commissioned.
Opononi Water Supply	Water	AUT.004369.01.03 AUT.007356.01.02	Abatement	13-Feb-20	4	Contravention of Water Shortage Direction EAC.069872.01	Daily readings Monday to Friday of water used by the 5 largest non-domestic water users shall also be taken and provided to the NRC by 5pm each Monday for the previous week.	EAC.069917.01	Current		
Opononi Water Supply	Water	AUT.004369.01.03 AUT.007356.01.02	Infringement	3-Jul-20	4	Failure to comply with the requirements of a Water Shortage Direction, notice number EAC	see abatement notice EAC.069917.01	EAC.070061.01	Current		
Kaikohe Water Supply	Water	AUT.004109.01.03 AUT.004046.03.02	Abatement	13-Feb-20	4	Contravention of Water Shortage Direction EAC.069870.01	Daily readings Monday to Friday of water used by the 5 largest non-domestic water users shall also be taken and provided to the NRC by 5pm each Monday for the previous week.	EAC.069918.01	Current		
Kaikohe Water Supply	Water	AUT.004109.01.03 and AUT.004046.03.02	Infringement	3-Jul-20	4	Failure to comply with the requirements of a Water Shortage Direction, notice number EAC.069860.01	see abatement notice EAC.069860.01	EAC.070059.01	Current		
Kaitaia Water Supply	Water	AUT.005112.01.03 AUT.002837.01.02	Abatement	13-Feb-20	4	Contravention of Water Shortage Direction EAC.069860.02	Daily readings Monday to Friday of water used by the 5 largest non-domestic water users shall also be taken and provided to the NRC by 5pm each Monday for the previous week.	EAC.069919.01	Current		
Kaitaia Water Supply	Water	AUT.005112.01.03 AUT.002837.01.02	Infringement	3-Jul-20	4	Failure to comply with the requirements of a Water Shortage Direction, notice number EAC.069870.01	see abatement notice EAC.069870.01	EAC.070060.01	Current		
Kawakawa WWTP	Wastewater	AUT.001168.08.01	Abatement	4-Feb-20	3 & 12	Bunded sludge disposal area non-compliant, and contractor not aware of conditions of consent.	The level of sludge within the bunded sludge disposal areas did not have a freeboard of no less than 200mm from the top of the bunds. The contractor undertaking the desludging (Conhur Ltd) did not have a copy of the resource consent and were not aware of the conditions of the consent.	EAC.069903.01	Current		This should be able to be cancelled - refer to correspondence with Lyndell and Peter Oliver. Rectification actions have been put in place.
Ahipara WWTP	Wastewater	AUT.003775.01.03, 02.02 and 03.02	Abatement	26-Mar-18	2	Leachate levels	The volume of leachate discharged to the aerated oxidation pond from the Ahipara Landfill shall not exceed 10 cubic meters per day.	EAC.068583.01	Current		Submitted request to cancel on 26 April 2018. Confirm - I don't think this was accepted?
Ahipara WWTP	Wastewater	AUT.003775.01.03 and AUT.003775.03.02	Abatement	6-Sep-17	10	FC levels at compliance point	Enforcement officer found on 17 August 2017 that the discharge from the wastewat treatment system was not complying with condition 10 of the resource consent in particular the faecal coliform median and 90 percentile levels.	EAC.067878.01	Cancelled	28/11/2019	
Russell WWTP	Wastewater	8339	Abatement	6-Mar-17		Ecoli levels at compliance point	Contravention of condition 6 of AUT.008339.01.03 relating to discharge from the wastewater treatment plant. In particular ecoli levels.	EAC.067566.01	Current		
Kerikeri Sports Complex	Treated Wastewater		Abatement	16-Dec-16	?	Exceed discharge limits on multiple occasions	Gross exceedance of discharge consent limit of 5 cubic metre in a 24-hour period. Dates from 7 October to 10 October 2016.	EAC.067359.01	Current		
Kerikeri Sports Complex	Treated Wastewater		Infringement	8-Oct-16		Exceed discharge limits		EAC.067362.01	Paid/Closed		
Kerikeri Sports Complex	Treated Wastewater		Infringement	9-Oct-16		Exceed discharge limits		EAC.067363.01	Paid/Closed		
Opononi WWTP	Wastewater	AUT.002667	Abatement	20-Apr-16	19	Ecoli levels at compliance point	Discharge from the wastewater treatment system was not complying with condition 19 of the resource consent, in particular the ecoli median and 90 percentile levels.	EAC.066718.01	Current		
Kaitaia WWTP	Wastewater	932	Abatement	20-Apr-16		Untreated discharges	The discharge of untreated wastewater from the Kaitaia reticulated wastewater network into the Tarawhaturoa Stream, Kaitaia.	EAC.066717.01	Current		
Paihia WWTP	Wastewater	1108	Abatement	21-Nov-12		Ammonia Levels		ICE424129	Cancelled	25-Sep-14	
Paihia WWTP	Wastewater	AUT.00108.01.03	Abatement	26-Oct-16	13f	Ammonia Levels		EAC.067129.01	Cancelled	10/08/2020	

Released under the Official Information Act 1982